

Certificate

Registration No.: PV 60030854

Page 1

Report No.: 15037686.001

License Holder:

YINGLI ENERGY (CHINA) COMPANY LIMITED

No. 3399 Chaoyang North Road

Baoding, Hebei 071000

P.R. China

Product:

PV Module

Type:

YL***C-24b (***=180-215, in increment of 5)

YL***C-27b (***=205-240, in increment of 5)

YL***C-30b (***=225-270, in increment of 5)

YL***C-33b (***=250-295, in increment of 5) YL***C-36b (***=270-325, in increment of 5)

Manufacturing plant:

YINGLI ENERGY (CHINA) COMPANY LIMITED

No. 3399 Chaoyang North Road

Baoding, Hebei 071000

P.R. China

Basis:

X

IEC 61730-1:2004

IEC 61730-2:2004

EN 61730-1:2007

EN 61730-2:2007

"Photovoltaic (PV) module safety

qualification"



Factory Inspection

To document the consistent quality of the product factory inspections are

performed periodically



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).

- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.

- The fire test (IEC 61730-2 / MST 23) was not performed.

-The details of the factory inspection are documented in report No. 15036290.001

Conditions

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 01 June 2015.



Dipl.-Ing. M. Adrian

Cologne, 02 June 2010

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg / Contact: + 49 221 806 2477 email: enertest@de.tuv.com



Certificate

Registration No.: PV 60030854 Page 5 Report No.: 15037686.015

License Holder:

YINGLI ENERGY (CHINA) COMPANY LIMITED

No. 3399 Chaoyang North Road Baoding, Hebei 071051

P.R. China

Product:

PV Module

Type:

YL***C-24b (***=220-225, in steps of 5)

YL***C-27b (***=245-250, in steps of 5)

YL***C-30b (***=275-280, in steps of 5)

YL***C-33b (***=300-310, in steps of 5)

YL***C-36b (***=330-340, in steps of 5)

Manufacturing Plant: YINGLI ENERGY (CHINA) COMPANY LIMITED

No. 3399 Chaoyang North Road Baoding, Hebei 071051

P.R. China

Basis:



IEC 61730-1:2004 IEC 61730-2:2004 EN 61730-1:2007

EN 61730-2:2007

"Photovoltaic (PV) module safety qualification"



Factory Inspection

To document the consistent quality of the product factory inspections are performed periodically



- · Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report No. 15036290.002
- Extension to higher output power.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 1 June 2015.



Dipl.-Ing. M. Adrian

Cologne, 18 January 2012